


Typical Residential Cross-Connections


- ◆ Hose Bibs
- ◆ Lawn Irrigation
- ◆ Jacuzzis
- ◆ Swimming Pools



M NM M N M P
 M B M N M P

External assemblies—to protect the City’s water from cross connection with any contaminants on the customer’s premises.

Internal assemblies—to protect the customer from potentially hazardous cross connections in their own system.



**Reduced Pressure
Backflow Device**

Your Responsibilities as a Property Owner

As a property owner you are responsible for protecting the water on your property. This responsibility starts at the water meter and includes your entire property’s water system. If you have any actual or potential cross connection to the City’s potable water system, you are required to have a backflow prevention device installed and tested annually. All costs associated with the installation, operation, maintenance and annual testing of your backflow prevention device is your responsibility. Termination of water services is an option of last resort for untested devices. However properties not in compliance with State of Idaho regulations for successful annual testing shall have water service to their home discontinued until backflow prevention devices are brought into compliance. The City of Eagle will make all reasonable efforts in helping each customer come into compliance with State and local regulations.

Finding a Certified Backflow Tester

Backflow testing must be completed by a State of Idaho certified backflow tester. It is the responsibility of the property owner to confirm their tester is currently certified by the Idaho Bureau of Occupational Licensing (IBOL) and that testing reports are submitted to the City in a timely manner. Check your local listings for backflow testers in our area.

IBOL can be reached at 208-334-3233 to confirm your tester’s certification.

Thank You!

The City of Eagle takes the protection of your drinking water supply very seriously. We appreciate your continued support and partnership in working with us to assure the delivery of safe drinking water to your home.

Idaho State Drinking Water regulations (IDAPA 58.01.08.552.6) require that all backflow assemblies are inspected annually. Properties with assemblies that have not been tested, have not been isolated or repaired or replaced, shall have water service to the failed assembly discontinued.

Certified test results are due no later than **June 10th** of each year. Failure to comply with the testing requirements by this due date could result in termination of water services to your home until such time as the test results are received.

**City of Eagle Water Department
660 E Civic Lane
or
PO Box 1520
Eagle, ID 83616**

**Phone: 208-489-8777
Fax: 208-939-6827**

Website: www.cityofeagle.org/water